

Intergration Options and need for metering in Solar Thermal Hybridization with Conventional plants






- Steag and it's services
- Integration options used in some existing plants
- Simulation study for finding the Solar share
- Need for metering

Steag's Activities



Steag Germany - Key figures (as of Dec. 2011)

- External sales **3,066 € m**
- Capital expenditure on fixed assets **1,283 € m**
- Employees **5,800**




Steag India Activities

- Engineering Consultancy
- O&M services – ~ 5000 MW
- System Technology – Simulators and Plant optimization systems
- Training and advisory services

Steag India – Solar activities

- Several DPRs and feasibilities
- Ebsilon Solar – Proprietary thermodynamic design software
- Solar simulator - with Trax
- Owners Engineer NTPC Anta
- Training on Solar – With IITJ

STEAG holds a strong position in the renewable energy market



Steag Projects



Wind

- Identification of specific projects



Solar

- 50 MW plant at Arenales



Biomass*

- since 2002
- #3 in Germany



Biogas

- since 2007
- First own biogas plant commissioned



Mine gas

- since 1908
- #1 in Germany



Geothermal

- since 1994
- #1 in Germany



Contracting


- since 1961
- #2 in Germany

Installed capacity		Plants
MW _{el}	MW _{th}	
66	154	13
177	139	108
--	71	2
77	905	100
319	1,271	223

Total

Steag's Arenales 50 MW plant in Spain

- Steag has a 26% stake
- O&M shall be done by Steag themselves
- Technical concept comparable to Andasol 3
- Capacity of the plant: 49.9 MW
- Wet cooling tower implemented
- Solar field with 156 Loops Parabolic Collectors
- Thermal Storage (salt) for up to 7h of full load operation
- Gross electricity production: about 170 GWhel p.a.
- Planned operation period: 40 years




➤ The implemented technical concept is state of the art for CSP plants in Spain

Approaches to hybridization

ISCC

1. **Solar heat → LP stage of turbine**
Superheated Steam of low P, T
 - replacing extractions from ST
2. **Solar heat → steam generator**
saturated steam
 - fossil fired superheating

Shams 1 – UAE



ISST

3. **Solar heat (300°C) → Feed-water pre-heaters**

Kuraymat – Egypt

Agua Prieta II – Mexico

Solar thermal hybrid plants in the world

Location	Start Production	Hybridization scheme		Method
Borges Termosolar Spain	Dec 2012	Biomass	Solar	Solar steam in CRH line
		2 X 22 MW _{th}		
ISCC Kuraymat Egypt	Jun 2011	Nat. gas	Solar	ISCC
		120 MW	20 MW	
Liddell Power Station Australia	Oct 2012	Coal	Solar	270°C, 55 bar fed into the existing coal plant
		4X500 MW	9 MW _{th}	
Agua Prieta II Mexico	2014	Nat. gas	Solar	ISCC
		464 MW	14 MW	
Shams 1 UAE	Mar 2013	Solar	Nat. gas	380°C steam boosted to 540°C by gas augmentation
		100 MW	Augmentation and backup	


Borges Termosolar – SPAIN

Biomass + Solar



- **Participants:** Abantia, Comsa EMTE
- **Scheme:** 2 x 22 MW_{th} biomass (main fuel)
183,120 m² solar-field aperture area
- **Turbine capacity:** 25 MW (gross); 22.5 MW (Net)
- **Solar-field inlet:** 293°C
- **Solar-field outlet:** 393°C
- **Advantage:**
 - reduction in biomass consumption
 - reduction in fuel-transport expenditure
 - easier integration in agro-land


Borges Termosolar - Layout



- **Participants:** NREA, Orascom/Flagsol
- **Scheme:** 120 MW combined cycle (Nat. gas)
20 MW solar input
131,000 m² mirror area
61 MW_{th} max.
- **Method:** Integrated solar combined cycle
- **HRSG and Solar HX:** Steam generation by solar HX
(pre-heater + evaporator) fed into HP steam drum
- **Turbine capacity:**
 - gas turbine: 74 MW
 - steam turbine: 60 MW @ 50 MJ/s solar heat
36 MW without solar heat
- **Solar-field inlet:** 293°C
- **Solar-field outlet:** 393°C

ISCC Kuraymat

Scope split and general concept



Liddell Power Station – AUSTRALIA


Coal + Solar



- **Participants:** Novatec Solar, Macquarie Generation
- **Scheme:**
 - 2000 MW coal
 - 9 MW_{th} solar input
 - 18,490 m² mirror area
- **Method:** 270°C, 55 bar from the 9 MW_{th} solar boiler fed into the existing 2000 MW coal fired power station
- **Technology:** LFR
- **Solar-field inlet:** 140°C
- **Solar-field outlet:** 270°C


- **Participants:** Abengoa Solar, Federal Electricity Commission
Abener/Teyma
- **Scheme:** 464 MW combined cycle (Nat. Gas)
14 MW_{el} solar input
85,000 m² mirror area
- **Method:** ISCC
330°C, 130 bar saturated steam from solar
Additional nat. gas duct burner included in CC
when solar field not in operation
- **Technology:** Parabolic trough

Agua Prieta II - Layout




- **Participants:** Masdar, Total, Abengoa Solar, Abener/Tyma, ADWEC
- **Scheme:** 100MW solar
627,840 m² mirror area
Nat. gas backup
- **Method:** Gas augmented solar thermal
380°C steam boosted to 540°C by gas powered heater
- **Technology:** Parabolic trough
- **Solar-field inlet:** 300°C
- **Solar-field outlet:** 400°C

Shams 1 - Layout



Source: Goebel, O., and F. Luque. "Shams one 100 MW CSP plant in Abu Dhabi: update on project status." *Concentrating Solar Power & Chemical Engineering Systems* (2012).

Simulation done for finding the solar share at different points of injection



Simulation results – Coal saving

Case	Coal Consumption (kg/s)	Reduction (kg/s)	Reduction (%)
Base Case	52.115		
LPH 3	51.907	0.21	0.40
LPH 4	51.691	0.42	0.81
HPH 1	51.207	0.91	1.74
HPH 2	50.691	1.42	2.73
CRH	51.193	0.92	1.77


Simulation results – Power reduction

Case	Coal Consumption (kg/s)	Power (MW)	Reduction (MW)	% reduction
Base Case	52.115	750.00		
LPH 3	51.907	746.95	3.05	0.41
LPH 4	51.690	743.73	6.27	0.84
HPH 1	51.207	736.47	13.53	1.80
HPH 2	50.691	735.76	14.24	1.90
CRH	51.193	736.27	13.73	1.83

Simulation results – Varying heat at a particular point

q solar (MW)	Power (MW)
50	749.333
45	748.068
40	746.738
35	745.400
30	744.042
25	742.669
20	741.292
15	739.912
10	738.530

Power generated vs Solar heat input



Need for Metering

- Injection of same amount of heat at different places has different equivalent power.
- There can be no standardized calculation for the equivalent power as it depends upon the HBD of the plant.
- The equivalent power at a particular injection point may or may not vary linearly with the changing heat input. This means that with varying DNI, the equivalent power conversion ratio would be different.
- The plant load percent also changes the solar equivalent power as the cycle efficiency varies with load.
- The special tariff / subsidy / RPO would be permissible only for the power produced and not for the heat produced.
- So a methodology is required for accurately calculating the equivalent power.
- We present a model based approach for this based on our Epsilon software.



Thank You

... Ideas & Solutions for Tomorrow

steag